

## Test and troubleshooting from AWT/AWH-V5+

Serial no iu.:	-	Mode setting (Heating/cooling/Hot water):	Varme/varmtvann
Serial no ou:	-	Driftsmåte ved avlesing:	Varmtvann
Date of nstallation:		Disp.temp.:	Set temp.:

To be able to read the units operation values, press and hold both the "arrow buttons" simultaneously for 5 seconds. After 5 seconds you will enter the menu below. Read and put in the value in the table below and use the "arrow up" button to move to the next value. Please check that the code in the display correspond with the code in the table.

Code	Meaning	Value 1	Value 2	Value 3	Value 4	Value 5
01	Ambient temperature					
02	Hot Water temperature					
03	Cooling water temperature					
04	Unit outlet temperature					
05	Unit inlet temperature					
06	System 1 indoor coil temperature					
07	Heating water temperature					
08	System 2 indoor coil temperature					
09	Room temperature					
10	System 1 voltage (V)					
11	System 1 current (A)					
12	System 1 compressor speed (Hz)					
13	System 1 outdoor coil temperature					
14	System 1 comp. discharge temp.					
15	System 1 suction temperature					
16	System 1 evaporating pressure					
17	System 1 condensing pressure					
18	System 2 voltage (V)					
19	System 2 current (A)					
20	System 2 compressor speed (Hz)					
21	System 2 outdoor coil temperature					
22	System 2 comp. discharge temp.					
23	System 2 suction temperature					
24	System 2 evaporating pressure					
25	System 2 condensing pressure					
26	System 1 EEV position					
27	System 2 EEV position					
28	Failure bit					
29	Protection bit					
30	N/A					